



Product Service

CERTIFICATE

No. B 034962 0316 Rev. 00

Holder of Certificate: **SynQor Inc.**
155 Swanson Road
Boxborough MA 01719-1316
USA

Certification Mark:



Product: **Rechargeable lithium-ion battery**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 72163169-000

Valid until: 2026-07-11

Date, 2021-07-26

(David Dorfner)

CERTIFICATE

No. B 034962 0316 Rev. 00

Model(s): BAT-0400-M-1U-000, BAT-0400-H-1U-000, 8INR22/71-4

Brand Name: SynQor

Parameters:

Rated Input Voltage:	33.6 V AC
Rated Input Current:	16.8 A
Rated Output Voltage:	28.8 V DC
Rated Output Current:	14 Ah
Rated Output Power:	375 Wh
Charge:	0° to 45°C
Discharge:	-20° to 55°C

Model Differences:

- **BAT-0400-M-1U-000** are **BAT-0400-H-1U-000** are identical except for model designation and minor software differences.
- Type Reference Number **8INR22/71-4** is considered equivalent to models BAT-0400-M-1U-000, BAT-0400-H-1U-000.

Tested according to: IEC 62133-2:2017